



Kimley-Horn
and Associates, Inc.

February 26, 2014

Mr. Stuart Bass
Planning Director
Town of Pittsboro
P.O. Box 759
Pittsboro, NC 27313

■
Suite 600
333 Fayetteville Street
Raleigh, North Carolina
27601

Re: Proposed Medical Office Building and Hospice at *Chatham Park*
Wastewater Allocation Requests

Dear Mr. Bass:

This letter is an official request on behalf of *Chatham Park* for water and wastewater allocations for two facilities now being proposed. The first is a 25,000 square foot medical office building (MOB) to be built east of Suttles Road. The second is the Chatham Hospice to be built on the south side of Russett Run. A map of these locations is attached.

The allocation requested for the MOB is 250 GPD/practitioner/shift * 16
practitioner * 1 shift = 4,000 gallons per day.

The allocation requested for Hospice is 300 GPD/ bed * 20 beds
= 6,000 gallons per day.

These allocation requests are based on established design flow rates from NCDENR. Additional details related to these projects are, or will, be included in the proposed site plans.

We appreciate your consideration of these requests. For additional information or questions please contact Jordan Brewer, PE at 919-653-6654.

Sincerely,

W. Jordan Brewer



2/26/14