


NOTE:

1. FOR EASEMENT INSTALLATIONS, FINISH TO GRADE INDICATED ON PLANS USING PRECAST CONE SECTION.
2. AIR RELEASE MANHOLES WILL BE SUBJECT TO VACUUM TESTING.
3. INSTALL VALVE OFFSET FROM MANHOLE LID TO ALLOW MAINTENANCE ACCESS.



EFFECTIVE: 10/01/16

COMBINATION AIR RELEASE AND VACUUM VALVES

TOWN OF PITTSBORO
STANDARD CONSTRUCTION DETAIL
STANDARD NO: PW-03-009