APPENDIX C

Historical DMR Data

TOWN OF PITTSBORO
WASTEWATER TREATMENT PLANT PERFORMANCE DATA (NPDES PERMIT NC00020354)
JANUARY 2011 - DECEMBER 2011

Month, Year	Average Daily Flow (mgd) Influent	Average Daily Flow (mgd) Effluent	pH, units	Temperature Celsius	BOD_5 mg/L		TSS, mg/L		NH_3-N, mg/L		Total Nitrogen, mg/L	Total P, mg/L		TKN, mg/l	Nitrate/Nitrite, mg/l	Fecal Coliform, #100/ml	Dissolved Oxygen, mg/L
			Eff.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Eff.	Inf.	Eff.	Eff.	Eff.	Eff.	Eff.
Jan. 2011	0.415	0.289	6.6-7.11	12.60	329.00	6.40	340.00	11.90	31.10	0.18	26.27		1.53	2.50	23.75	7.00	8.41
Feb. 2011	0.425	0.309	6.72-7.16	13.20	304.00	3.30	369.00	4.90	29.40	0.19	24.89		1.60	1.60	23.33	1.00	8.18
Mar. 2011	0.467	0.332	6.64-7.41	14.90	331.00	2.20	466.00	6.00	23.24	0.17	22.29		1.30	1.30	20.95	9.00	8.12
Apr. 2011	0.465	0.342	6.39-7.24	17.40	390.00	1.00	465.00	1.30	20.25	0.12	21.05		1.60	1.30	19.79	1.00	7.56
May. 2011	0.463	0.285	6.24-7.23	20.40	248.00	3.30	250.00	3.80	19.00	0.24	25.69		1.40	1.40	24.25	1.00	7.19
Jun. 2011	0.400	0.205	6.38-7.10	24.00	249.00	2.60	206.00	2.90	20.50	0.27	27.31		1.63	1.60	25.72	2.00	6.96
Jul. 2011	0.393	0.192	6.16-8.51	26.00	292.00	3.10	350.00	8.80	23.76	1.23	33.98		1.59	3.10	31.46	3.00	6.80
Aug. 2011	-	0.263	6.16-8.48	26.40	285.00	3.40	324.00	19.00	25.40	0.16	32.96		2.17	1.80	29.96	3.00	7.11
Sep. 2011	0.401	0.243	6.02-7.73	24.60	271.00	2.90	308.00	8.10	21.11	0.35	31.82		1.55	1.60	30.23	2.00	7.52
Oct. 2011	0.432	0.273	6.52-8.33	21.10	368.00	4.40	368.00	12.70	17.51	1.66	29.10		0.98	2.90	24.86	7.00	7.78
Nov. 2011	0.477	0.301	6.34-7.08	17.80	391.00	4.00	390.00	1.30	22.87	1.39	22.58		0.52	3.60	21.06	6.00	7.86
Dec. 2011	0.484	0.315	6.29-7.29	15.70	347.00	2.20	284.00	2.50	20.86	0.15	25.99		0.81	1.20	24.35	1.00	7.99
Averages	**0.438**	**0.279**	**-**	**19.51**	**317.08**	**3.23**	**343.33**	**6.93**	**22.92**	**0.51**	**26.99**	**#DIV/0!**	**1.39**	**1.99**	**24.98**	**3.58**	**7.62**

TOWN OF PITTSBORO
WASTEWATER TREATMENT PLANT PERFORMANCE DATA (NPDES PERMIT NC00020354)
JANUARY 2012 - DECEMBER 2012

Month, Year	Average Daily Flow (mgd) Influent	Average Daily Flow (mgd) Effluent	pH, units	Temperature Celsius	BOD_5 mg/L		TSS, mg/L		NH_3-N, mg/L		Total Nitrogen, mg/L	Total P, mg/L		TKN, mg/l	Nitrate/Nitrite, mg/l	Fecal Coliform, #100/ml	Dissolved Oxygen, mg/L
			Eff.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Eff.	Inf.	Eff.	Eff.	Eff.	Eff.	Eff.
Jan. 2012	0.455	0.285	6.64-7.38	14.50	348.00	2.30	327.00	3.20		0.14	24.18		1.29	1.10	23.53	2.00	7.39
Feb. 2012	0.420	0.279	6.73-7.24	13.90	348.00	2.40	387.00	4.00		0.13	23.20		1.53	1.40	21.82	2.00	9.41
Mar. 2012		0.326	6.51-7.33	16.60	300.00	0.00	337.00	0.20		0.15	21.90		1.12	0.80	19.73	1.00	8.93
Apr. 2012	0.373	0.254	6.39-7.31	18.90	400.00	0.00	316.00	0.00		0.06	28.17		1.72	1.00	27.15	3.00	8.42
May. 2012	0.377	0.247	6.56-6.64	21.70	446.00	2.10	432.00	0.00		0.12	34.03		1.52	1.00	33.06	4.00	8.21
Jun. 2012	0.322	0.232	6.83-7.37	25.30	351.00	2.30	297.00	2.70		0.09	32.74		1.39	1.20	31.58	6.00	8.71
Jul. 2012	0.319	0.249	6.81-7.49	26.60	286.00	2.50	271.00	0.00		0.11	36.13		1.75	1.30	34.74	5.00	8.15
Aug. 2012	0.328	0.254	6.36-7.19	26.60	398.00	0.00	381.00	0.00		0.11	33.91		2.18	1.10	32.78	2.00	7.66
Sep. 2012	0.355	0.289	6.52-7.5	24.60	320.00	2.30	353.00	0.00		0.13	30.49		1.34	0.90	29.55	1.00	7.93
Oct. 2012	0.402	0.324	6.35-7.01	21.10	255.00	0.20	215.00	0.00		0.08	29.34	22.50	1.11	0.80	28.53	1.00	8.37
Nov. 2012	0.370	0.243	6.65-6.99	17.30	309.00	0.20	217.00	0.00		0.00	33.04	22.26	1.36	1.10	31.93	1.00	9.05
Dec. 2012	0.419	0.290	6.59-7.02	16.60	283.00	0.20	197.00	0.00		0.15	28.94	20.92	1.19	1.60	27.38	0.00	9.14
Averages	**0.376**	**0.273**	**-**	**20.31**	**337.00**	**1.21**	**310.83**	**0.84**	**#DIV/0!**	**0.11**	**29.67**	**21.89**	**1.46**	**1.11**	**28.48**	**2.33**	**8.45**

TOWN OF PITTSBORO
WASTEWATER TREATMENT PLANT PERFORMANCE DATA (NPDES PERMIT NC00020354)
JANUARY 2013 - DECEMBER 2013

Month, Year	Average Daily Flow (mgd) Influent	Average Daily Flow (mgd) Effluent	pH, units	Temperature Celsius	BOD_5 mg/L		TSS, mg/L		NH_3-N, mg/L		Total Nitrogen, mg/L	Total P, mg/L		TKN, mg/l	Nitrate/Nitrite, mg/l	Fecal Coliform, #100/ml	Dissolved Oxygen, mg/L
			Eff.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Eff.	Inf.	Eff.	Eff.	Eff.	Eff.	Eff.
Jan. 2013	0.451	0.330	6.68 - 6.98	14.40	255.00	0.20	173.00	0.00		0.31	19.14		1.45	1.10	18.24	0.00	9.29
Feb. 2013	0.533	0.383	6.63 - 7.0	13.10	228.00	0.20	152.00	0.00		0.14	15.49		1.50	1.40	14.09	0.00	9.44
Mar. 2013	0.495	0.354	6.59 - 7.09	13.20	230.00	0.20	151.00	0.00		0.14	14.65		1.68	2.50	12.13	0.00	9.36
Apr. 2013	0.515	0.362	6.67 - 7.09	16.80	239.00	0.21	177.00	1.64		0.14	23.45		0.56	1.53	21.92	0.00	8.79
May. 2013	0.482	0.342	6.77 - 7.02	19.50	259.00	0.39	220.00	0.21		0.00	22.00		0.25	1.05	20.95	0.00	8.49
Jun. 2013	0.518	0.391	6.74 - 7.04	22.80	267.00	0.00	164.00	0.00		0.00	20.22	1.10	0.30	0.84	19.38	0.00	8.07
Jul. 2013	0.503	0.409	6.75 - 6.75	24.10	257.00	0.94	239.00	1.03		0.65	19.86	3.15	0.27	1.86	18.00	0.00	7.90
Aug. 2013	0.405	0.241	6.78 - 6.99	25.00	276.00	0.00	283.00	0.00		0.00	26.91	3.25	0.19	0.98	25.93	0.00	7.79
Sep. 2013	0.395	0.256	6.68 - 7.08	24.10	238.00	0.36	277.00	0.00		0.00	28.40	3.19	0.11	0.83	27.70	0.00	8.22
Oct. 2013	0.401	0.264	6.94 - 7.18	21.50	280.00	0.18	282.00	0.00		0.00	31.12	3.15	0.13	1.02	30.10	0.00	8.36
Nov. 2013	0.389	0.280	6.55 - 6.92	17.80	300.00	0.25	252.00	0.00		0.04	27.77	3.18	1.17	1.17	26.60	0.00	8.92
Dec. 2013	0.491	0.397	6.45 - 7.0	15.10	286.00	1.06	238.00	0.00		0.23	20.04	2.91	1.86	1.74	18.30	0.00	9.18
Averages	**0.465**	**0.334**	**-**	**18.95**	**259.58**	**0.33**	**217.33**	**0.24**	**#DIV/0!**	**0.14**	**22.42**	**2.84**	**0.79**	**1.34**	**21.11**	**0.00**	**8.65**

TOWN OF PITTSBORO
WASTEWATER TREATMENT PLANT PERFORMANCE DATA (NPDES PERMIT NC00020354)
JANUARY 2014 - DECEMBER 2014

Month, Year	Average Daily Flow (mgd) Influent	Average Daily Flow (mgd) Effluent	pH, units	Temperature Celsius	BOD_5 mg/L		TSS, mg/L		NH_3-N, mg/L		Total Nitrogen, mg/L	Total P, mg/L		TKN, mg/l	Nitrate/Nitrite, mg/l	Fecal Coliform, #100/ml	Dissolved Oxygen, mg/L
			Eff.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Eff.	Inf.	Eff.	Eff.	Eff.	Eff.	Eff.
Jan. 2014	0.561	0.447	6.46 - 7.36	12.30	235.00	1.06	174.00	1.35	13.95	0.80	16.46	2.39	1.00	2.49	13.97	6.29	9.61
Feb. 2014	0.603	0.459	6.34-6.93	12.00	208.00	1.05	145.00	1.51		0.07	16.08	2.68	1.07	1.15	14.94	16.10	9.60
Mar. 2014	0.617	0.519	6.37-6.91	12.50	224.00	4.89	125.00	6.28	13.10	1.14	18.00	2.49	0.79	3.81	14.20	5.70	9.42
Apr. 2014	0.606	0.512	6.64-6.84	15.80	216.00	0.76	108.00	1.12	14.20	0.01	20.49	2.52	0.19	1.32	19.17	0.00	8.94
May. 2014	0.504	0.466	6.48-6.89	20.00	265.00	1.28	191.00	1.30	17.44	0.00	22.50	6.18	0.45	1.34	21.17	1.81	8.51
Jun. 2014	0.399	0.324	6.58-7.09	23.60	302.00	0.26	224.00	0.00	21.61	0.00	23.12	6.48	0.42	1.20	21.92	0.00	7.98
Jul. 2014	0.416	0.259	6.64-6.95	25.00	318.00	0.00	246.00	0.00	17.10	0.00	28.03	6.59	0.64	1.14	26.89	1.00	7.97
Aug. 2014	0.493	0.323	6.67-7.47	24.24	325.00	0.00	216.00	2.32	15.96	0.60	21.29	7.52	0.59	1.20	20.09	0.00	8.01
Sep. 2014	0.430	0.285	6.94-7.18	24.28	262.50	0.00	223.00	0.00	18.42	0.00	19.85	7.08	0.46	1.24	18.61	0.00	7.98
Oct. 2014	0.450	0.282	6.83-7.21	21.26	296.53	0.00	210.31	0.00	18.05	0.03	18.70	7.24	0.51	1.17	17.53	0.23	8.40
Nov. 2014	0.470	0.306	6.65-6.93	17.50	313.58	0.54	258.75	1.40	16.69	0.06	20.76	6.66	1.57	1.19	19.57	2.83	8.98
Dec. 2014	0.524	0.401	6.63-6.91	15.09	210.00	0.00	209.00	0.00	16.49	0.02	16.50	7.67	1.53	1.54	14.96	0.43	9.26
Averages	**0.506**	**0.382**	**-**	**18.63**	**264.63**	**0.82**	**194.17**	**1.27**	**16.64**	**0.23**	**20.15**	**5.46**	**0.77**	**1.57**	**18.58**	**2.87**	**8.72**

TOWN OF PITTSBORO
WASTEWATER TREATMENT PLANT PERFORMANCE DATA (NPDES PERMIT NC00020354)
JANUARY 2015 - DECEMBER 2015

Month, Year	Average Daily Flow (mgd) Influent	Average Daily Flow (mgd) Effluent	pH, units	Temperature Celsius	BOD_5 mg/L		TSS, mg/L		NH_3-N, mg/L		Total Nitrogen, mg/L	Total P, mg/L		TKN, mg/l	Nitrate/Nitrite, mg/l	Fecal Coliform, #100/ml	Dissolved Oxygen, mg/L
			Eff.	Eff.	Inf.	Eff.	Inf.	Eff.	Inf.	Eff.	Eff.	Inf.	Eff.	Eff.	Eff.	Eff.	Eff.
Jan. 2015	0.602	0.433	7.09-7.3	12.800	205.000	<2	134.000	<2.5	14.100	0.230	11.520	4.100	1.350	1.030	10.490	1.000	9.570
Feb. 2015	0.515	0.400	7.03-7.25	11.530	215.000	2.330	163.000	3.300	17.680	0.100	15.870	3.970	1.460	1.370	14.500	1.000	9.690
Mar. 2015	0.637	0.537	6.91-7.21	13.170	213.000	2.630	149.000	4.200	15.160	0.500	19.310	3.120	1.010	1.420	17.890	1.100	9.660
Apr. 2015	0.824	0.551	7.02-7.25	16.510	241.000	<2	183.000	4.000	14.900	0.730	17.430	3.590	0.360	3.480	13.950	14.600	8.860
May. 2015	0.468	0.344	6.41-6.82	20.180	290.920	1.220	214.600	1.870		0.062	22.750		0.310	1.350	21.400	1.380	8.440
Jun. 2015	0.403	0.273	6.55-6.77	23.980	270.300	<2	231.000	<2.5		<0.1	29.710		0.330	1.340	28.370	1.850	7.910
Jul. 2015	0.387	0.275	6.57-7.04	25.450	244.280	<2	242.140	0.260		0.060	29.780		0.270	1.030	28.750	1.750	8.000
Aug. 2015	0.353	0.233	6.35-6.86	25.900	263.330	<2	232.500	<2.5		<.04	33.150		0.520	1.150	32.000	1.300	7.920
Sep. 2015	0.389	0.281	6.4-6.98	24.590	247.140	0.000	251.420	<2.5		<.04	32.320		0.480	1.320	31.000	1.390	8.140
Oct. 2015	0.496	0.422	6.18-7.14	20.900	225.460	0.410	230.760	1.560		0.057	23.530		0.590	1.135	22.400	1.620	8.560
Nov. 2015	0.685	0.631	6.03-7.18	18.320	130.720	3.030	148.360	8.180		0.720	18.920		1.110	1.420	17.500	3.270	8.860
Dec. 2015	0.645	0.585	6.08-6.61	17.120	223.640	0.400	168.570	0.570		0.019	20.050		0.770	1.050	19.000	1.000	9.040
Averages	**0.534**	**0.414**	**-**	**19.204**	**230.816**	**1.431**	**195.696**	**2.993**	**15.460**	**0.275**	**22.862**	**3.695**	**0.713**	**1.425**	**21.438**	**2.605**	**8.721**

Town of Pittsboro 2014 Water and Sewer Billings

	Jan-14		Feb-14		Mar-14		Apr-14		May-14		Jun-14		Jul-14		Aug-14		Sep-14		Oct-14		Nov-14		Dec-14	
	Units	Usage	Units	Usage	Units	Usage	Units	Usage	Units	Usage	Units	Usage	Units	Usage	Units	Usage	Units	Usage	Units	Usage	Units	Usage	Units	Usage
Sewer - Inside	1,340	4,068,210	1,344	4,933,130	1,347	4,166,980	1,348	3,971,990	1,352	4,428,720	1,355	4,435,240	1,355	4,914,100	1,357	4,648,180	1,366	4,730,950	1,374	4,496,910	1,376	4,940,760	1,387	4,337,930
Sewer - Outside	1	2,110	1	3,300	1	2,850	1	2,350	1	3,240	1	2,400	1	2,680	1	2,300	1	2,950	1	2,640	1	3,280	1	2,630
Flat Rate Sewer	11	0	11	0	11	0	11	0	11	0	11	0	12	0	12	0	12	0	12	0	12	0	12	0
Sewer Inside Lg. Meter	8	17,600	8	18,880	8	19,650	8	18,720	8	19,360	8	18,320	8	21,100	8	21,300	8	23,860	8	21,050	8	22,130	8	36,910
RESIDENTIAL SUBTOTAL	1,360	4,087,920	1,364	4,955,310	1,367	4,189,480	1,368	3,993,060	1,372	4,451,320	1,375	4,455,960	1,376	4,937,880	1,378	4,671,780	1,387	4,757,760	1,395	4,520,600	1,397	4,966,170	1,408	4,377,470
Sewer - Inside	203	967,590	203	1,057,780	201	1,127,430	200	1,090,250	200	136,980	201	1,056,750	203	1,114,200	202	1,045,950	203	1,038,380	203	979,850	203	1,092,600	204	955,770
Flat Rate Sewer	2	0	2	0	2	0	2	0	2	0	2	0	2	0	3	0	3	0	3	0	3	0	3	0
Sewer Inside Lg. Meter	428	2,405,720	428	2,534,860	428	2,450,390	428	2,398,820	428	2,581,960	429	2,391,610	429	2,380,550	429	2,459,020	429	2,350,420	429	2,318,210	429	2,711,730	429	2,412,610
Sewer Outside Lg. Meter	2	70,950	2	74,950	2	77,900	2	71,600	2	99,400	2	105,900	2	94,750	2	86,150	2	88,100	2	79,100	2	98,600	2	84,000
COMMERCIAL SUBTOTAL	635	3,444,260	635	3,667,590	633	3,655,720	632	3,560,670	632	3,818,340	634	3,554,260	636	3,589,500	636	3,691,120	637	3,476,900	637	3,377,160	637	3,902,930	638	3,452,380
SEWER SUBTOTAL	1,995	7,532,180	1,999	8,622,900	2,000	7,848,200	2,000	7,553,730	2,004	8,269,660	2,009	8,010,220	2,012	8,527,380	2,014	8,262,900	2,024	8,234,660	2,032	7,897,760	2,034	8,869,100	2,046	7,829,850
Water - Inside	1,424	4,308,560	1,428	5,261,530	1,431	4,440,630	1,432	4,206,450	1,435	4,697,330	1,439	4,698,770	1,440	5,239,040	1,442	5,005,980	1,450	5,066,250	1,459	4,819,050	1,462	5,251,530	1,472	4,628,160
Water - Outside	144	408,210	144	443,860	144	449,340	144	368,950	144	397,390	146	396,950	145	432,630	146	432,040	145	455,230	145	390,020	147	401,460	147	386,590
Water Inside - Irrigation	18	5,690	18	0	18	0	18	1,520	18	17,790	18	99,690	18	235,290	18	221,060	18	210,130	18	162,310	18	136,180	18	84,720
Chapel Ridge	1	1,660,000	1	2,240,000	1	2,005,000	1	1,720,000	1	2,110,000	1	2,365,000	1	3,380,000	1	4,125,000	1	2,805,000	1	2,925,000	1	2,585,000	1	5,471,000
Inside Water Lg. Meter	8	17,600	8	18,880	8	19,650	8	18,720	8	19,360	8	18,320	8	21,100	8	21,300	8	23,860	8	21,050	8	22,130	8	36,910
RESIDENTIAL SUBTOTAL	1,595	[illegible]	1,599	[illegible]	1,602	[illegible]	1,603	[illegible]	1,606	[illegible]	1,612	[illegible]	1,612	[illegible]	1,615	[illegible]	1,622	[illegible]	1,631	[illegible]	1,636	[illegible]	1,646	[illegible]
Water - Inside	21	1,003,830	217	1,086,880	215	1,155,280	214	126,180	214	1,192,390	215	1,102,850	217	1,187,890	217	1,125,590	218	116,800	218	1,042,000	218	1,150,410	219	989,680
Water - Outside	9	11,530	9	14,350	9	17,110	9	15,780	9	17,870	9	34,150	9	35,680	9	33,570	10	32,390	11	72,950	10	65,130	10	17,850
Water Inside - Irrigation	6	24,520	6	23,000	6	0	6	0	6	0	6	137,150	6	262,800	6	36,750	7	52,550	7	57,700	7	61,950	7	33,000
Reuse Water	2	1,094,390	2	1,887,350	2	1,776,000	2	2,287,240	2	1,834,930	2	1,241,100	2	1,021,890	2	1,205,900	2	1,546,040	2	1,516,010	2	1,526,590	2	1,127,980
Inside Water Lg. Meter	432	2,567,020	432	2,653,260	432	2,555,990	432	2,505,220	432	2,733,460	433	2,769,160	433	2,726,150	433	2,791,420	433	2,640,520	433	2,583,810	433	2,898,430	433	2,577,810
Outside Water Lg. Meter	2	70,950	2	74,950	2	77,900	2	71,600	2	99,400	2	105,900	2	94,750	2	86,150	2	88,100	2	79,100	2	98,600	2	84,000
Large Meter Inside Irrigation	0	0	0	0	0	0	0	0	0	0	1	25,080	1	85,690	1	3,530	1	10,060	1	9,320	1	260	1	510
COMMERCIAL SUBTOTAL	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
WATER SUBTOTAL	2,263	11,172,300	2,267	13,704,060	2,268	12,496,900	2,268	12,321,660	2,271	13,119,920	2,280	12,994,120	2,282	14,722,910	2,285	15,088,290	2,295	14,046,930	2,305	13,678,320	2,309	14,197,670	2,320	15,438,210

2014-2015 Pittsboro WWTP By-Pass Events (from NCDEQ)

Region	Report Number	Type Of Incident	Report Type	County	Date Reported
Raleigh	201400045	Bypass	Bypass 5 Day.	Chatham	01/11/2014
Raleigh	201400045	Bypass	Incident	Chatham	01/11/2014
Raleigh	201400282	Bypass	Incident	Chatham	02/15/2014
Raleigh	201400956	Bypass	Incident	Chatham	05/15/2014
Raleigh	201401413	Bypass	Bypass 10 Day.	Chatham	08/11/2014
Raleigh	201401413	Bypass	Bypass 5 Day.	Chatham	08/11/2014
Raleigh	201401413	Bypass	Incident	Chatham	08/11/2014
Raleigh	201401435	Bypass	Bypass 5 Day.	Chatham	08/09/2014
Raleigh	201401435	Bypass	Incident	Chatham	08/09/2014
Raleigh	201500321	Bypass	Bypass 10 Day.	Chatham	03/02/2015
Raleigh	201500321	Bypass	Bypass 5 Day.	Chatham	03/02/2015
Raleigh	201500321	Bypass	Incident	Chatham	03/02/2015
Raleigh	201500351	Bypass	Bypass 5 Day.	Chatham	03/05/2015
Raleigh	201500351	Bypass	Incident	Chatham	03/05/2015
Raleigh	201500528	Bypass	Bypass 5 Day.	Chatham	04/10/2015
Raleigh	201500528	Bypass	Incident	Chatham	04/10/2015
Raleigh	201500562	Bypass	Bypass 5 Day.	Chatham	04/20/2015
Raleigh	201500562	Bypass	Incident	Chatham	04/20/2015
Raleigh	201501248	Bypass	Bypass 5 Day.	Chatham	10/03/2015
Raleigh	201501248	Bypass	Incident	Chatham	10/03/2015
Raleigh	201501615	Bypass	Bypass 5 Day.	Chatham	11/10/2015
Raleigh	201501615	Bypass	Incident	Chatham	11/10/2015
Raleigh	201501981	Bypass	Bypass 5 Day.	Chatham	12/23/2015
Raleigh	201501981	Bypass	Incident	Chatham	12/23/2015
Raleigh	201502118	Bypass	Incident	Chatham	12/30/2015