



ELEVATION



BOX

- NOTES:**
- 1) TO ENSURE POSITIVE DRAINAGE, THE VAULT SHALL HAVE AN OPEN BOTTOM TO ALLOW DRAINAGE THROUGH STONE.
 - 2) STANDARD RECLAIMED WATER HOSE BIB AND BOX SHALL BE MAINTAINED ON PRIVATE PROPERTY BY OWNER.
 - 3) PRECAST CONCRETE BOX WITH ALUMINUM ACCESS HATCH WILL BE AN ACCEPTABLE ALTERNATIVE WITH APPROVAL OF THE TOWN OF PITTSBORO.
 - 4) THE INTERIOR OF THE BOX SHALL BE STENCILED WITH THE WORDS, **CAUTION RECLAIMED WATER - DO NOT DRINK.**
 - 5) ALL BRASS COMPONENTS SHALL BE 'NO LEAD' BRASS MEETING UNS C89833 AS PER ASTM B584.

DIMENSIONS (INCHES)	
A	B
10 1/4"	15 1/2"



EFFECTIVE: 10/01/16

STANDARD RECLAIMED WATER HOSE BIB AND BOX

TOWN OF PITTSBORO
 STANDARD CONSTRUCTION
 DETAIL
 STANDARD NO: RW-06-007