

a. WWTP Facility Name Pittsboro WWTP  
 b. WWTP Facility Permit # NC0020354

	<i>All flows are in MGD</i>
c. WWTP facility's permitted flow	0.750
d. Paper Flow	0.167
e. WWTP facility's actual avg. flow	0.523
f. Total flow for this specific request	0.005
g. Total actual and obligated flows to the facility	0.695
h. Percent of permitted flow used	93%

<b>Remaining Capacity Available for Allocation =</b>	<b>0.055</b>
--	--------------

Gallons per day available                      **54,795**