



- NOTES:**
1. VALVE OPERATOR EXTENSION SHALL BE INSTALLED IN ALL CASES WHERE THE VALVE OPERATOR IS GREATER THAN 6 FOOT DEPTH FROM THE SURFACE.
 2. ADDITIONAL JOINT RESTRAINT REQUIRED IN EACH DIRECTION (NOT SHOWN) FOR INLINE VALVE TO OPERATE AS A DEAD END.
 3. HORIZONTAL GATE VALVES SHALL ONLY BE INSTALLED WHERE VERTICAL ALIGNMENT IS NOT POSSIBLE DUE TO DEPTH, MINIMUM CLEARANCE, OR OTHER CONFLICTS.

RESILIENT WEDGE GATE VALVE ASSEMBLY FOR HORIZONTAL INSTALLATIONS