



- NOTES:**
1. FLUSHING DEVICE SHALL HAVE A SELF DRAINING, DOUBLE CHECK VALVE FOR FREEZE PROTECTION.
  2. PIPING SHALL BE 2 INCH STAINLESS STEEL TUBING.
  3. AREA AROUND FLUSHING DEVICE SHALL BE GRADED TO FACILITATE FLOW AWAY FROM THE SPLASH PLATE.
  4. ENTIRE ASSEMBLY SHALL BE LOCATED IN A DEDICATED EASEMENT OR AS DIRECTED.

**STANDARD AUTOMATIC FLUSHING DEVICE**