



CLEANOUT SHALL BE PLACED AT RIGHT-OF-WAY OR EDGE OF EASEMENT. DO NOT INSTALL CLEANOUT INSIDE A FENCE.

NOTES:

1. INSTALLATION TO BE THE SAME AS FOR STANDARD 4 INCH SEWER SERVICE CONNECTION.
2. ALL 6 INCH SEWER SERVICES MUST GO TO A MANHOLE.
3. APPROVED MARKING TAPE SHALL BE INSTALLED FOR ALL SERVICE CONNECTIONS FROM THE MAIN LINE TO THE CLEANOUT FOR ALL NEW CONSTRUCTION OR RETROFIT INSTALLATIONS USING OPEN TRENCH METHODS.
4. WITHIN TOWNHOUSE DEVELOPMENTS, SERVICE CONNECTIONS SHALL BE LOCATED WITHIN 4 FEET OF DRIVEWAYS, OR UNDER DRIVEWAYS.

6" TO NO MORE THAN 30" ABOVE INVERT. FOR CONNECTIONS TO 16" AND LARGER MAINS PLACE SERVICE INVERT AT CROWN ELEVATION OF MAIN.

CONCRETE TROUGH TO BE BUILT TO DIRECT FLOW FROM 6" CONNECTION TO EFFLUENT PIPE

SECTION VIEW

TOWN OF PITTS ORO

STANDARD CONSTR CTION
DETAIL

STANDARD NO: SS 0 15 0

EFFECTIVE: / /2