



- NOTES:**
- ENGINEER OF RECORD SHALL SPECIFY ELECTRICAL DETAILS, EQUIPMENT RACK, CONDUIT, CONTROL PANELS, PULL BOX, AND FLOW TRANSMITTER.
 - ENGINEER OF RECORD SHALL COORDINATE PLC LOGIC WITH OWNER.
 - ACCESS HATCH SHALL BE CENTERED OVER METER.
 - ACCESS HATCH AND METER VAULT SHALL BE RATED FOR H-20 LOADING.

EFFECTIVE: ; ; ;

TOWN OF PITTSBORO
STANDARD CONSTRUCTION
DETAIL
STANDARD NO: SS-04-0