



- NOTES:**
1. PUMP STATIONS SHALL MEET ALL STATE MINIMUM DESIGN REQUIREMENTS AND BE APPROVED BY THE ENGINEERING DIRECTOR.
 2. WET WELLS SHALL BE EPOXY COATED (80 mils).
 3. ALL PIPE AND VALVE SIZES DISPLAYED ARE MINIMUM SIZES, AND THE ACTUAL SIZES WILL BE DETERMINED BY THE HYDRAULIC DESIGN OF A PROFESSIONAL ENGINEER.
 4. PROVIDE LEVERAGE BAR FOR 2 INCH NUT TO BE LEFT IN VALVE VAULT.

WET WELL AND VALVE VAULT (PROFILE VIEW)