



PLAN VIEW

SEE SHEET 2 OF 2 FOR
PROFILE VIEW

- NOTES:**
1. PUMP STATIONS SHALL MEET ALL STATE MINIMUM DESIGN REQUIREMENTS AND BE APPROVED BY THE DIRECTOR OF UTILITIES.
 2. WET WELLS SHALL BE EPOXY COATED (80 mils).
 3. ALL PIPE AND VALVE SIZES DISPLAYED ARE MINIMUM SIZES, AND THE ACTUAL SIZES WILL BE DETERMINED BY THE HYDRAULIC DESIGN OF A PROFESSIONAL ENGINEER.
 4. ISOLATION VALVE WILL BE INCLUDED DOWNSTREAM OF FLOW METER VAULT WHEN A FLOW METER IS REQUIRED.

EFFECTIVE: / /22