



NOTES:
 1. VALVE OPERATING NUT MUST BE EXTENDED SO THAT THE DEPTH IS NO GREATER THAN 6 FEET FROM THE SURFACE USING AN EXTENSION KIT FROM THE VALVE MANUFACTURER.



STANDARD RECLAIMED WATER VALVE BOX INSTALLATION

TOWN OF PITTSBORO
 STANDARD CONSTRUCTION
 DETAIL
 STANDARD NO: RW-06-013

EFFECTIVE: 8/22/22