



- NOTES:**
1. POTABLE WATER METER SHALL BE FITTED WITH DUAL CARTRIDGE CHECK VALVE.
 2. METERS ARE TO BE PLACED IMMEDIATELY INSIDE OF R/W OR UTILITY EASEMENT LINE.
 3. ALL PIPE AND APPURTENANCES LOCATED OUTSIDE OF THE R/W OR EASEMENT ARE MAINTAINED BY THE PROPERTY OWNER.
 4. APPROVED MARKING TAPE SHALL BE INSTALLED FOR ALL SERVICE CONNECTIONS FROM MAIN LINE TO METER FOR ALL NEW CONSTRUCTION OR RETROFIT INSTALLATIONS USING OPEN TRENCH METHODS.
 5. IN TOWNHOUSE DEVELOPMENTS, RECLAIMED SERVICES SHALL BE WITHIN 4 FT OF DRIVEWAYS TO MINIMUMZE CONFLICTS



**STANDARD RECLAIMED WATER SERVICE CONNECTIONS
IN DEFINED RECLAIMED SERVICE AREAS**

TOWN OF PITTSBORO
STANDARD CONSTRUCTION
DETAIL
STANDARD NO: RW-06-001