

Replaced Meter

5/31/13

TOWN OF PITTSBORO WATER DEPARTMENT  
WORK ORDER

Date: 5/31/13 Routing Seq: 1/3070

Name: Joe J. Torbert Account: 407

Location: 687 N.C. Hwy 87 North

Meter # 1105278486 New Meter # 1834682072

Reading: 5736 Reading: 0

Work to be performed: change meter and Test

Work Completed: new E-coder meter installed

Date Completed: 5/31/13 Tagged: Yes  No  Signed: Ronald

OTHER:

Meter Covered Up  Tagged: Yes  No   
Meter Broken  Other \_\_\_\_\_

Reason: \_\_\_\_\_  
Materials Used: \_\_\_\_\_  
Total Labor: \_\_\_\_\_ Charge To Customer: \_\_\_\_\_

Signed: \_\_\_\_\_

BACKFLOW PREVENTION ASSEMBLY

Test: Passed:  Failed:

If failed, was it repaired? Yes  No

Did the Town get a full report? Yes  No  Signed: \_\_\_\_\_

METER TEST SHEET READINGS

Name: \_\_\_\_\_

Address: 687 N. 87

Meter # 1105278486 Reading: 5736

Start	<u>57367.0</u>	Start	<u>57378.0</u>	Start	<u>57388.0</u>
Low Flow gpm	<u>2.5</u>	Med Flow gpm	<u>7.5</u>	Hi Flow gpm	<u>14</u>
Stop	<u>57377.05</u>	Stop	<u>57388.0</u>	Stop	<u>57398.0</u>
%	<u>100.05%</u>	%	<u>100.0%</u>	%	<u>100.0%</u>

Signed: Ronald

Signed: Chn

RECEIVED MAY 31 2013

